



A P P R O V A L S ®

Certificate of Approval

Addendum

Certificate No.: SAA121420

Date of Issue: 1 August 2012

Class Description: Non-Declared

Product Description: Grid-connected Inverter

Additional Models

TSG4KTL

TSG5KTL

Description

Similar to TSG3KTL except rated input 210-420Vdc, Max 20A and output 20A 4000W.

Similar to TSG3KTL except rated input 260-420Vdc, Max 20A and output 25A 4600W.

A handwritten signature in dark ink, appearing to read 'Gina', written over a horizontal line.

For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd Electrical Product Safety Certification Scheme as accredited by JAS-ANZ under ISO/IEC Guide 65 certifies that the electrical product described on this certificate complies with the minimum electrical safety requirements for which the application has been made.

JAS-ANZ

