



# 太阳能产品认证证书

证书编号: CQC12024067552

### 申请人名称及地址

天能逆变技术有限公司  
香港九龙观塘海滨道151-153号广生行中心6楼10室

### 制造商名称及地址

天能逆变技术有限公司  
香港九龙观塘海滨道151-153号广生行中心6楼10室

### 生产企业名称及地址

天宝电子(惠州)有限公司 (V015880)  
广东省惠州市惠城区水口镇东江工业区

### 产品名称和系列、规格、型号

并网光伏逆变器

TSG50K3: 直流输入: DC 450V-850V, Max. 125A; 交流输出: 3N~ 380V 50Hz, 76A, 50kW

### 产品标准和技术要求

CNCA/CTS 0006-2010

### 认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合CQC33-461239-2011认证规则的要求, 特发此证。

发证日期: 2012年02月20日

有效期至: 2016年02月20日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。



主任: \_\_\_\_\_



## 中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

T 0001328



# SOLAR PRODUCT CERTIFICATE

No.: CQC12024067552

### NAME AND ADDRESS OF THE APPLICANT

TEN SOURCES SOLAR ELECTRICITY LIMITED.  
RM 10.6/F KWONG SANG HONG CTR 151-153 HOI BUN RD KWUN TONG KLN HONG KONG

### NAME AND ADDRESS OF THE MANUFACTURER

TEN SOURCES SOLAR ELECTRICITY LIMITED.  
RM 10.6/F KWONG SANG HONG CTR 151-153 HOI BUN RD KWUN TONG KLN HONG KONG

### NAME AND ADDRESS OF THE FACTORY

Ten Pao Electronics(Huizhou) Co.,Ltd.(V015880)  
Dongjiang Industrial Area,Shuikou Town, Huizhou City, Guangdong Province, P.R.China

### NAME, MODEL AND SPECIFICATION

Grid-Connected PV Inverter  
TSG50K3: Input:DC 450V-850V, Max.125A; Output:3N~ 380V 50Hz, 76A, 50kW

### THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

CNCA/CTS 0006-2010

### CERTIFICATION MODEL

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned products have met the requirements of certification rules CQC33-461239-2011.

Date of issue: Feb.20,2012

Date of expiry: Feb.20,2016

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.



President:

Wang Kejiao



## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China



T 0001328